

**MONTGOMERY TOWNSHIP
SOMERSET COUNTY, NEW JERSEY**


**ADDENDUM NO. 1
TO
CONTRACT DOCUMENTS**

for

**STAGE II WASTEWATER TREATMENT PLANT
HEADWORKS UPGRADE PROJECT**

BID PACKAGE #B01-2018

February 2, 2018



Timothy D. Bradley, P.E.
NJ. P.E. Lic. No. 34109



**MONTGOMERY TOWNSHIP
SOMERSET COUNTY, NEW JERSEY**

**ADDENDUM NO. 1
TO
CONTRACT DOCUMENTS**

for

**STAGE II WASTEWATER TREATMENT PLANT
HEADWORKS UPGRADE PROJECT**

BID PACKAGE #B01-2018

The following changes and additional information are hereby made part of the Contract Documents:

Pre-Bid Meeting:

A pre-bid meeting and site visit was held at the Stage II Wastewater Treatment Plant on January 30, 2018 at 10:00 a.m. A copy of the meeting minutes and attendance list is attached.

Specifications:

1. Section 15370, delete Part 2.01.B.

Drawings:

1. Sheet M-2, add the following to the end of Note 2:

“Exposed and buried service water piping shall be Type 304 stainless steel”.

**Montgomery Township Stage II WWTP Headworks Upgrade Project
Pre-Bid Meeting Minutes**

Date / Time: January 30, 2018 – 10:00 am
Location: Stage II Wastewater Treatment Plant
Owner: Montgomery Township
Engineer: Kleinfelder

1. Introductions

Representatives of the Owner and the Engineer were introduced.

2. Agenda

- Project Scope
- Bid Submission
- Highlighted Requirements
- Site Visit

3. Overview of Project Scope

- Raising the perimeter walls of the Headworks structure
- Installation of a new stairway, handrails and access platforms
- Installation of a new mechanical screen and screenings washer/compactor
- Installation of a new wet well mixer
- Relocation of an existing grinder
- Replacement of existing grit removal and air diffusion equipment
- Associated electrical and instrumentation work

4. Overview of Bid Submission Requirements

- Bids will be opened at 11 am on 2/15/18.
- Refer to the Required Documents Checklist presented in Forms, page 1 for items to be submitted with the Bid.

HIGHLIGHTED REQUIREMENTS

5. Contract Period

- 330 calendar days from the Notice To Proceed

6. Need to Maintain Operations during Construction

- Refer to Section 01005 – Maintenance of Plant Operations
- General work sequence is presented in Section 01005. Contractor shall prepare a detailed plan.

7. Handling Questions/Issuance of Addenda

- All questions related to interpretation or requirements of the drawings and specifications must be submitted in writing to Gail Smith, Township Engineer. See Instructions to Bidders, page 4.
 - Phone 908 359-8211
 - Fax – 908 359-2006
 - Email – gsmith@twp.montgomery.nj.us
- As described in the Instructions to Bidders, the final date and time for submission of questions is February 1 at 4 pm.
- Contractors are encouraged to submit questions as soon as possible to maximize the likelihood that there is sufficient time for all questions to be addressed.
- An addendum will be issued to address questions.

8. QUESTIONS

- What are the requirements for the bypass pumping system? *Refer to Specification Section 01501 for system requirements. As noted in this Section, the system shall pump from the manhole upstream of the Headworks structure to the Aeration Tank. Assume a water surface elevation of approximately 44.0 at the manhole and a discharge elevation of 64.0 at the Aeration Tank for estimating pumping head requirements.*

9. SITE VISIT

- A tour of the Headworks facility was conducted.

SIGN-IN SHEET
 PRE-BID MEETING AND SITE VISIT
 MONTGOMERY TOWNSHIP
 STAGE II WWTP HEADWORKS UPGRADE PROJECT
 January 30, 2018

NAME	COMPANY	PHONE / EMAIL
Kensch roeder	I.H.C.	908 879 1348 Ken.Schroeder@ ironhillsconstruction .com
Edwonn QUATTARA	Aqualite c	310 920 3118 edwonnara@aqualite.com
Jason Kiernan	Montgomery Twp	908-299-6133 jkiernan@montgomerynj.us
Bob Jensen	MONTGOMERY TWP.	(908) 296-3455 RJENSEN@MONTGOMERY.NJ.US
Johann Rubenars	Mont Twp	732-306 2666 Jrubenars@montgomerynj.us
GAIL SMITH	MONTGOMERY TWP	908 359 8211 x294 GSMITH@TWP.MONTGOMERY.NJ.US
Sara Urbanczyk	GA Fleet	surban@gafleet.com 646 326 2775